

TAMILNADU FIRE AND RESCUE SERVICE
DEPARTMENT
NO OBJECTION CERTIFICATE

No: 68/VB/EGM/2021
DATE: 05/02/2021

EGMORE FIRE & RESCUE SERVICES STATION.

SUBJECT: NOC FROM FIRE & RESCUE SERVICES DEPARTMENT-
EGMORE FIRE & RESCUE SERVICE STATION-TO
ESTABLISH/TO RECOGNITION FOR SCHOOL.

REF: 1) GO.NO.122 SCHOOL EDUCT (1) DEPT DATE: 14.09.2004.
2) GO.NO.123 SCHOOL EDUCT (2) DEPT DATE: 14.09.2004.
3) THE PRINCIPLE APPLICATION RECEIVED ON DATE:01.02.2021.

With reference to the above Go and Application Door NO:7, HARRINGTON ROAD, CHETPET, CHENNAI-600 031. The established school M/S: SIR MUTHA SCHOOL. The school was inspected by the Egmore Station Officer Mr.A.JAMES ARUL PRAKASH Concerned of this department on 03.02.2021 and then observed that all fire prevention and fire safety arrangements as provided in the premises found in good condition. So the department gave NOC for this school to Recognition / to establish it.

CONDITIONS

1. *This License is valid for One year from the date of issue.*
2. *Fire Safety Systems should be maintained in good working condition.*
3. *Mock drill to be conducted periodically with the help of local fire brigade.*
4. *Any erection of permanent or temporary structure should be intimated to this department.*
5. *A trained Fire Service Person, preferably retired one should be appointed.*
6. *Further to limit the occupant load and to ensure better fire and life safety measures the following additional measures are insisted.*
 - a) *Building occupancy capacity should not be more than 4 people per Sq. meter as per the National Building Code-2005.*
 - b) *The staircase treads and flooring shall be treated with rough finish (grooving) to avoid falling of children.*
 - c) *As per Para 6.3 of the BIS Standards IS 14435:1997 as the classrooms have only one entrance, the capacity of the class rooms shall have to be limited to 45 students.*
 - d) *Periodical maintenance and care should be taken to maintain all fire protection equipments.*

